



TYPE APPROVAL CERTIFICATE
형식승인증서

Certificate No. : HMB02696-FP001 **Date of Approval** : 24th May, 1997.

Product : Fire-Proof Cable Penetration

Manufacturer : AIK Flammadur Brandschutz GmbH
Otto-Hahn-Strasse 5, D 34123 Kassel, Germany

Product Description : GEAQUELLO-Sealing Compound System
Type : E950
Grade : A-60 Class
Drawings : 271.149 498.GZ(1/4) ~ 271.149 498.GZ(4/4)
271.142 891.GZ(1/4) ~ 271.142 891.GZ(4/4)

Intended for : Cable Transits in A-60 Class Bulkheads & Decks

Approval Condition : 1. This approval is granted on the basis of the fire test report no. GV95.47.1 and GH95.27.1 performed at TUV Brandhaus in Hamburg.
2. No product certificate required.

THIS IS TO CERTIFY that the above-mentioned product has been approved in accordance with the relevant requirement of this Society's Rules and/or of the recognized standards as follows and entered in the "List of Approved Manufacturers and Type Approved Equipments".

Pt 8, Ch 1, Sec 2 of the Rules for Classification, Steel Ships & IMO FTP Code, Annex 1, Part 3.

This Certificate is valid until 23rd day of May, 2007.

Issued at Daejeon, Korea on 25th September, 2002.

KOREAN REGISTER OF SHIPPING

T. Lim
Manager of Machinery Dept.

Note : 1 : The approval will be automatically suspended and the Certificate become invalid from the expiry date of the Certificate in the event that the extension has not been granted or is not under attendance for completion of the renewal survey.
2 : Any significant changes of products and/or manufacturing process render this certificate invalid.